

FAMLICO COUNTY HEALTH DEPARTMENT
 DIVISION OF ENVIRONMENTAL HEALTH
 PO BOX 306
 BAYBORO NC 28515

AUG 08 2006

IMPROVEMENT PERMIT
 (VALID 5 YEARS)

Owner: ALLEN W. MILLER C/O CAROLYN BELLIS/BETH FRAZER
 Owner Address: 300 SOUTH MAIN STREET
 Owner Address(2): ROARING SPRING PA 16673
 Owner Phone #: 249-9800
 Property Address: 45 HUDWELL LANE
 PIN: J082-056-2
 Record # 58448
 Establishment Type: Home
 Type of Well: Public Well
 Design Flow (GPD): 360

Initial Site TYPE IIIb 6 LWC @ SOFT
 Wastewater System: Conventional Pipe
 Long Term Acceptance Rate (GPD/SQFT): 0.4
 Trench Width: 3 FT
 Trench Spacing (OC): 9 FT
 Trench Bottom From NGL: -12 IN
 Septic Tank Volume: 1000 GAL

* SEE ATTACHMENT FOR SEPTIC SYSTEM LOCATION.

REPAIR SITE

* REPAIR EXEMPT ACCORDING TO PREVIOUS PERMIT

PROR TO THE ISSUANCE OF THE CONSTRUCTION AUTHORIZATION A SITE PLAN MUST BE PROVIDED SHOWING EXACT LOCATION OF RESIDENCE ALONG WITH DIMENSIONS.


IF ANY CHANGES OCCUR TO PROPERTY WITHOUT PROR APPROVAL FROM THE ENVIRONMENTAL HEALTH SECTION THE IMPROVEMENT PERMIT WILL BE REVOKED.

Authorized Agent: Michael Bulth R-5 Date 8/5/2006

Civilized Bldg RS 8-5-2006

SCALE = 1/4" = 40'


MB 7, PG 22



NOT TO SCALE

N34°06'00"E 167.36' TO R/W INT. OF HUDNELL LN & SR 1317

①



HUDNELL LANE

CAMP CREEK
S.E. CARTERS

NOTES:

FOR REFERENCE SEE
DB 342, PG 166
MB 7, PG 22

THE RATIO OF PRECISION (W)
CALCULATED AT 1:10,000

